

DUCT EXCEL PRE - INSULATED DUCT PANEL

Clean Technology, Clean Living



HVAC System

Aiming for better health

Heating, Ventilation and Air Conditioning (HVAC), Sick Building Syndrome, Indoor Air Quality and Green building concept have become of major concerns to human health in recent years.


HVAC industry has gone through dynamic changes to keep pace with the remarkable environment development.

Air Ducting is the skeleton of HVAC system where the techniques have been, internationally, accepted in view of the fact that it is fulfilling the demand for better, cleaner and faster air ducting system.

Above features classify pre-insulated ducting system eligible for Green Buildings.

Air duct system fabricated with **Pre-Insulated Duct panels** guarantees excellent air quality, increasing ducting system efficiency, which improves living environment.

The American Society of Heating, Refrigeration, and Air-conditioning Engineers (ASHRAE) Standard 62.1, Ventilation for Acceptable Indoor Air Quality, lists strategies for improving IAQ through mold and microbial growth prevention.



Product


Pre-Insulated Duct Panel (PID Panel)

DUCT EXCEL Pre-Insulated Duct Panel is your best solution of proper and suitable Air Duct System for clean air environment of Heat Ventilation and Air Conditioning (HVAC) System – 100% fiber free.


In comparison of traditional Air Duct System, there are many advantages of PID Duct Panel covering of lower initial cost, lower weight of duct & support, saving installation cost and time, long life span, and reduction of operating costs.

Through innovation of PID Duct Panel, its properties can protect many factors including:

- Excellent Fire Performance- 'Class 0' by British Standard 476 (BS476 Part 6 & 7)
- No leakage from duct connection
- Corrosion resistant
- Saving energy from excellent thermal conductivity
- A bit difference of air pressure from beginning to ending
- Resistant to Moisture Ingress, low water absorption, low humidity, and Fungi-free
- Tough enough for making elbow bend
- Saving maintenance cost.
- Eco-friendly
- Economical



PIR Panel Cross Section



Pre-Insulated Duct Panel Imported Machinery, Technology and Raw Materials

Imported Production Machinery and Technology

Through more than 18 years of Pre-Insulated Duct Panel manufacturing experiences from SAKE Co., Ltd. – South Korea* who has accumulated its own skills and knowledge in the PIR industry, we have imported their production machine and technology for local production.

Production Machinery is not only modern technology, energy saving but also environmentally friendliness. Our machine produces technologically innovative and high quality PID panels accurately and on a timely basis. The technique, quality and practical values of SAKE MACHINERY are leading in PID insulation industry, which is one of the best PID panel machineries in the world.

This superior technology particularly related to 100% water based PIR system and fire retardant foam with cutting edge technology. **Our clean technology provides you high standard of clean living area.**

Furthermore our raw materials have been imported for complete manufacturing solutions including of chemical ingredients and chemical formulas.

Therefore, **Duct Excel PID Panel** is high quality, proper functionality and weather resistant product.

*SAKE Co., Ltd. is the largest pre-insulated duct system and PIR insulation panel manufacturer in South Korea.



Factory in Nakornnayok Province,
45 km. from Bangkok

Advantages

Pre-insulated panels consist of sandwich structure of Aluminium – Poly-isocyanurate foam – Aluminium layers. Internationally recognized manufacturers presented this panel and accepted by ASHRAE as the perfect thermal insulator.

Pre-insulated panels are the first of decades of research and development around the world.

Visually pleasant : It is neat product and looks stylish with surroundings by all means.

Anti-microbial : Pre-insulated ducting system is very much hygienic and less extent to be contaminated by germs and microbes.


Lightweight : The weight of the pre-insulated panels is much lighter than other ducting method. No need for any additional insulation.

Easy to install : This system is simple, fast and easy to fabricate and also in maintenance phase.

“Easy Installation
Corrosion Resistant
Economical
Anti-microbial”



Light of weight! but Strong!!



Neat product and looks stylish

Technical Specifications

LEED V4 & V4.1 BETA

MODEL	APA-L 	APA	APAX	SPA	SAPA
ALUMINIUM FOIL					
Surface (Thickness - Microns)	Both Sides : <i>Embossed Aluminium Foil (80)</i>	Both Sides : <i>Embossed Aluminium Foil (80)</i>	Outer Face : <i>Embossed Aluminium Foil with Antibacterial Coating (80)</i>	Outer Face : <i>Metal Sheet or G.I. sheet (200)</i>	Outer Face : <i>Embossed Aluminium Foil (80)</i>
			Inner Face : <i>Embossed Aluminium Foil (80)</i>	Inner Face : <i>Embossed Aluminium Foil (80)</i>	Inner Face : <i>Smooth Aluminium Foil (180)</i>
Color Reference	Silver	Silver	Green / Silver	Gray / Silver	Silver
Weight per Unit Area	0.25 kg/m²				
Thermal Conductivity	0.021 W/m-k				
Flexural Strength	954 kPa				
Compression Strength	283 kPa				
Water Absorption	0.28 %				
PIR FOAM					
Thickness	20 mm.- 25 mm.				
Density	50±2 kg/m³				
Generic Type	Polyisocyanurate (PIR)				
Product Reference	Pre-insulated Duct Panel (PID)				
Color Reference	Beige				

List of Test Reports and Certifications

Description	Test Result	Test Method	Institution
PID PANELS			
Thermal Conductivity	0.021 W/m-k	ASTM C518-15	SGS
Density	51.02 kg/m ³	ASTM D1622	Department of Science Service
Flexural Strength	954 kPa	ASTM D203-05a	Exova, Canada
Compression Strength	283 kPa	ASTM D1621-16	Exova, Canada
Water Absorption	0.28 %	ASTM C209	Exova, Canada
Toxicity Index	2.75	NES 713	Interscience Fire Laboratory, UK
Vertical Flammability	V-0	UL94v	Interscience Fire Laboratory, UK
Horizontal Burning Foam Material	HF-1	UL94H	Department of Science Service
Fire Propagation Index	Class 0 (Index: 3.2)	BS 476 Part 6 1989+A1: 2009	Exova Warrington fire, UK
Spread of Flame	Class 1 (Index: <50 mm.)	BS 476 Part 7: 1997	Exova Warrington fire, UK
Fire Classification	Class 0	BS 476 Part 6 & 7	Exova Warrington fire, UK
Surface Burning Characteristics	Class A	ASTM E84-09c	Exova Warrington fire, Canada
Burning Test	0 sec.	UL181.11-2013	AWTA Limited
Aluminium Foil Anti-Bacterial Coating	Reduction 99.98% / 99.96%	ATCC 6538P / 8739	SGS
PVC FLANGES			
Vertical Flammability	V-0	UL 94V	Department of Science Service



Ignition



After 5 min
Temp measuring



After 10 min



After 20 min



After 30 min

Comparison Chart & Data sheet

Comparison Chart

	Steel Duct	Duct Excel PID Panel	Remark
Insulation	Insulation needed additionally	Self-insulation (0.022-0.024 w/m-k)	G/W 40T effect without extra insulation
Weight	0.8T:7.0 kg/m ² (G/W 24K 25T) 1.0T:8.3 kg/m ² (G/W 24K 25T)	1.38 – 1.44 kg/m ²	Only 1/5 weight of- steel duct
Noise	Noise generation and transfer	Excellent noise reducing effect	
Antibacterial	Easily contaminated	Antibacterial Function (Model APAX)	Epoxy coating (Antibacterial Ceramic – Zeolite contained)
Corrosion	Corrosion by humidity in air	No corrosion	Epoxy coating
Chemicals	Rapid corrosion by chemical reaction in air	Strong chemical resistance	Epoxy coating
Permissible Pressure	High pressure possible	Maximum 150 mmAg	
Permissible Velocity	High pressure possible	Below 15m/sec	
Leakage		Excellent	
Installation	Hard to cut, bend, and install Extra insulation needed	Easy to cut and light weight, able to bend No extra insulation needed	Low cost and save time
Exterior	Extra painting needed	Various colors	
Maintenance	Hard	Easy	
Durability	About 10 years	Semi-permanent	
Price	High	Reasonable	

Data sheet

Dimension	4,000 x 1,200 x 20 mm. or 2,400 x 1,200 x 20 mm.
Density	48-50 kg/m ³
Thickness of Aluminium Foil	80 micron
Weight	1.4 kg/m ²
Thermal Conductivity	0.022-0.024 w/m-k
Water Absorption	0.28 %
Temperature Range	-170°C to +140°C

Duct Excel Co., Ltd.

Head office address : 1622/1 Suthisan-vinitchai
Road, Huaykwang, Bangkok 10310, Thailand.

Tel : 02-277-8186, 02-693-0247

Mobile : 086-490 3437, 086-334-1487

Fax : 02-693-0869

Email : center@ductexcel.co.th

Factory address :

193 Moo 3, Rangsit-Nakornnayok Road,
Tambol Klongyai, Ampur Ongkarak,
Nakornnayok 26120, Thailand.

PID Accessories & Tools



ACF - 1001



ACF - 1002



ACF - 1003



ACF - 1004



ACF - 1005



ACF - 1006



ACF - 1008



ACS - 1001



ACS - 1002



ACS - 1003



ACS - 1004



ACS - 1006



ACS - 1007



ACC - 1002



ACK - 1006



ACK - 1007



ACT - 1001



ACA - 1001



ALUMINIUM TAPE



กาว PID



ซิลิโคน A - 700



List of Test Reports and Certifications	1.Thermal Conductivity ASTM C518-17
	2.Density ASTM D1622
	3.Toxicity Index NES713
	4.Vertical Flammability UL94v
	5.Horizontal Burning Foam Material UL94H
	6.Fire Propagation Index BS 476 Part 6 1989+1:2009
	7.Spread of Flame BS 476 Part 7:1997
	8.Fire Classification BS 476 Class 0 Summary PID
	9.Smoke Development ASTM E84
	10.Burning Test UL181.11-2013
	11.Aluminium Foil Anti-Bacterial Coating ATCC 6538P,8739
	12.PVC Flanges_Duct Excel UL 94V
	13.MIT (Made in Thailand)



No. 0307/ **16715**

To Duct Excel Co., Ltd.

The Department of Science Service presents the test report for the sample named "PID PANEL" Laboratory No. L64/08586.1 as the total of 1 sample with reference to the request No. L64/08586 dated 9 November 2021.

Enclosed herewith the following result avails for your acknowledgement.

Department of Science Service



Division of Engineering Materials

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th



TEST REPORT

Sample's name

PID PANEL

Mark / Brand

DUCT EXCEL

Laboratory No.

L64/08586.1

Test Result

Thermal conductivity at mean temperature of $(24 \pm 1) ^\circ\text{C}$, W/m-K 0.02118

Customer's name Duct Excel Co., Ltd.

Customer's address 1622/1 Sutthisan Winitchai Road, Huay Kwang, Bangkok 10310

Sample's description Silver color solid

Test date 16-19 November 2021

Test method ASTM C 518-17

Approved by

(Mr. Anon Pomprasit)

Scientist, Senior Professional Level

Reported by

(Mr. Kritsada Suttipan)

Scientist, Senior Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Page 2/2



No. 0307/ **3825**

To Duct Excel Co., Ltd.

The Department of Science Service presents the test report for the sample named "PIR Foam Panel" Laboratory No. L65/00812.1 as the total of 1 sample with reference to the request No. L65/00812 dated 31 January 2022.

Enclosed herewith the following result avails for your acknowledgement.



Division of Engineering Materials

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th



TEST REPORT

Sample's name

PIR Foam Panel

Mark / Brand

Duct Excel

Laboratory No.

L65/00812.1

Test Result

Density, kg/m³

51.02

Customer's name

Duct Excel Co., Ltd.

Customer's address

1622/1 Sutthisan Winitchai Road, Huay Kwang, Bangkok 10310

Sample's description

White - yellow solid

Test date

23 - 25 February 2022

Test method

ASTM D1622/D1622M-14

Approved by

(Mr. Anon Pomprasit)

Scientist, Senior Professional Level

Reported by

(Mr. Kritsada Suttipan)

Scientist, Senior Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand



Interscience Fire Laboratory

Building 63

Haslar Marine Technology Park

Haslar Road, Gosport

Hampshire PO12 2AG

United Kingdom

Tel. : +44 (0) 20 8692 5050

Fax.: +44 (0) 20 8692 5155

Email: firetesting@intersciencecomms.co.uk

Test Report: ICL/H18/9587 Rev 1

Defence Standard 02-713 Issue 3.

**Determination of the Toxicity Index of Products of combustion
from Small Specimens of Materials**

Sponsored By

Duct Excel Co., Ltd.

1622/1 Suthisan-Vinitchai Road, Huaykwang

Bangkok, Thailand 10310

Test Report: ICL/H18/9587 Rev 1

**Defence Standard 02-713 Issue 3.
Determination of the Toxicity Index of Products of combustion
from Small Specimens of Materials**

Sponsored By

Duct Excel Co., Ltd.
1622/1 Suthisan-Vinitchai Road, Huaykwang
Bangkok, Thailand 10310

1 Purpose of Test

To assess the performance of a material when it is tested in accordance with the procedures specified in Defence Standard 02-713 Issue 3 “Determination of the Toxicity Index of Products of Combustion from Small Specimens of Materials”.

2 Description of Test Specimen

The description of the specimen given above has been prepared from information provided by the sponsor of the test and Interscience Communications Ltd was not involved in any selection or sampling procedure.

The product was a nominally 13mm thick Polyisocyanurate (PIR) Rigid Foam.

The sponsor of the test did not provide further details relating to the composition of the material.

3 Conditioning of Test Specimens

The specimens were received on 25th June 2018

The test specimens were conditioned to constant mass at $23 \pm 2^{\circ}\text{C}$ and $50 \pm 10\%$ relative humidity for a minimum period of 24 hours prior to testing.

4 Date of Test

The test was performed on .

5 Test Procedure

Test was carried out in accordance with the procedure specified Defence Standard 02-713 Issue 3 “Determination of the Toxicity Index of Products of Combustion from Small Specimens of Materials”.

6 Test Results

The test results relate only to the behaviour of the specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Uncertainty measurement has not been taken into account when presenting the test results.

Average Specimen mass (g)	1.0020	Volume of the test chamber m³				0.75
Average Burn time (sec)		60				
Gas	Chemical formula	Concentration in chamber (ppm)	C_Θ (ppm)	C_f	C_Θ/C_f	
Carbon monoxide	CO	5	224.55	4000	0.06	
Carbon dioxide	CO ₂	5000	149701	100000	1.50	
Nitrogen oxides	NO _x	6	299.40	250	1.20	
Formaldehyde	HCHO	0	0.00	500	0.00	
Ammonia	NH ₃	0	0	750	0.00	
Acrylonitrile	CH ₂ CHCN	0	0	400	0.00	
Hydrogen cyanide	HCN	0	0.00	150	0.00	
Phenol	C ₆ H ₅ OH	0	0	250	0.00	
Sulphur dioxide	SO ₂	0	0.00	400	0.00	
Hydrogen sulphide	H ₂ S	0	0	750	0.00	
Hydrogen chloride	HCl	0	0.00	500	0.00	
Hydrogen bromide	HBr	0	0.00	150	0.00	
Hydrogen fluoride	HF	0	0	100	0.00	
Toxicity Index						2.75

Note : “0” Indicates below the limit of detection.

7 Observations

No significant phenomena was observed.

8 Conclusion


When tested in accordance with the procedure specified in Defence Standard 02-713 Issue 3 the material shows a Toxicity index value of 2.75 per 100 grammes of product.

Prepared by

A handwritten signature in black ink, appearing to read "C. B. Chong", with a horizontal line underneath.

**C. B. Chong
Fire Scientist**

Approved by

A handwritten signature in black ink, appearing to read "S. Kumar", with a horizontal line underneath.

**S. Kumar
Technical Manager**

Date of Issue: 19th July 2018

Date of issue Revision 1: 5th October 2018.

Test No 1					
Specimen mass (g)	1.0023	Volume of the test chamber m ³			0.75
Burn time (sec)	60				
Gas	Chemical formula	Concentration in chamber (ppm)	C ₀ (ppm)	C _f	C ₀ /C _f
Carbon monoxide	CO	5	224.48	4000	0.06
Carbon dioxide	CO ₂	5000	149656	100000	1.50
Nitrogen oxides	NO _x	6	299.31	250	1.20
Formaldehyde	HCHO	0	0.00	500	0.00
Ammonia	NH ₃	0	0	750	0.00
Acrylonitrile	CH ₂ CHCN	0	0.00	400	0.00
Hydrogen cyanide	HCN	0	0.00	150	0.00
Phenol	C ₆ H ₅ OH	0	0	250	0.00
Sulphur dioxide	SO ₂	0	0.00	400	0.00
Hydrogen sulphide	H ₂ S	0	0	750	0.00
Hydrogen chloride	HCl	0	0.00	500	0.00
Hydrogen bromide	HBr	0	0	150	0.00
Hydrogen fluoride	HF	0	0	100	0.00
Toxicity Index					2.75

Table 1a

Background concentration (ppm)		
CO	CO ₂	NO _x
2	3000	2

1. "0" stands for not detected. Concentration was below the limit of detection of the individual colorimetric tubes.
2. Concentration in the chamber values given in the Table 1 for CO, CO₂ and NO_x are inclusive of background values given in Table 1a.

Test No 2					
Specimen mass (g)	1.0017	Volume of the test chamber m ³			0.75
Burn time (sec)	60				
Gas	Chemical formula	Concentration in chamber (ppm)	C ₀ (ppm)	C _f	C ₀ /C _f
Carbon monoxide	CO	5	224.62	4000	0.06
Carbon dioxide	CO ₂	5000	149745	100000	1.50
Nitrogen oxides	NO _x	6	299.49	250	1.20
Formaldehyde	HCHO	0	0.00	500	0.00
Ammonia	NH ₃	0	0	750	0.00
Acrylonitrile	CH ₂ CHCN	0	0	400	0.00
Hydrogen cyanide	HCN	0	0.00	150	0.00
Phenol	C ₆ H ₅ OH	0	0	250	0.00
Sulphur dioxide	SO ₂	0	0.00	400	0.00
Hydrogen sulphide	H ₂ S	0	0	750	0.00
Hydrogen chloride	HCl	0	0.00	500	0.00
Hydrogen bromide	HBr	0	0	150	0.00
Hydrogen fluoride	HF	0	0	100	0.00
Toxicity Index					2.75

Table 2a

Background concentration (ppm)		
CO	CO ₂	NO _x
2	3000	2

1. "0" stands for not detected. Concentration was below the limit of detection of the individual colorimetric tubes.
2. Concentration in the chamber values given in the Table 2 for CO, CO₂ and NO_x are inclusive of background values given in Table 2a.



Interscience Fire Laboratory

Building 63

Haslar Marine Technology Park

Haslar Road, Gosport

Hampshire PO12 2AG

United Kingdom

Tel. : +44 (0) 20 8692 5050

Fax.: +44 (0) 20 8692 5155

Email: firetesting@intersciencecomms.co.uk

Test Report: ICL/H18/9586 Rev 1
Test for flammability of Plastic Materials
For Parts in Devices and Appliances
UL 94 Standard for safety
Section 8: Vertical burning test;
V-0, V-1, or V-2

Sponsored By

Duct Excel Co., Ltd.

1622/1 Suthisan-Vinitchai Road, Huaykwang

Bangkok, Thailand 10310

Test Report: ICL/H18/9586 Rev 1
Test for flammability of Plastic Materials
For Parts in Devices and Appliances
UL 94 Standard for safety
Section 8: Vertical burning test;
V-0, V-1, or V-2

Sponsored By
Duct Excel Co., Ltd.
1622/1 Suthisan-Vinitchai Road, Huaykwang
Bangkok, Thailand 10310

1 Purpose of Test

To assess the performance of specimens cut from a polymeric sheet when tested in accordance with the procedure specified in UL 94 Section 8 "Vertical burning test" for V-0, V-1, or V-2 rating.

2 Description of Test Specimens

The description of the specimen given below has been prepared from information provided by the sponsor of the test and Interscience Communications Ltd was not involved in any selection or sampling procedure. All values quoted are nominal, unless tolerances are given. All values quoted are nominal, unless tolerances are given.

The product was a nominally 13mm thick Polyisocyanurate (PIR) Rigid Foam.

The sponsor of the test did not supply further details relating to the composition of the material that was tested.

3 Conditioning of Specimens

The specimens were received on 25th June 2018

The first set of 10 specimens were conditioned for a minimum of 48 hours prior to testing at $23 \pm 2^{\circ}\text{C}$ and $50 \pm 5\%$ RH, before testing. A second set were conditioned for a minimum of 168 hours at $70 \pm 1^{\circ}\text{C}$ before being placed into a drying desiccator for 1 hour at ambient temperature, before testing.

4 Date of Test

The test was performed on 16th July 2018

5 Test Procedure

The test was performed in accordance with the procedures specified in UL 94 Section 8 Sub section 8.2 to 8.6 and this report should be read in conjunction with that Standard.

6 Test Results

The test results relate only to the behaviour of the specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and will therefore invalidate the test results.

The results for specimens conditioned at 23 ± 2 °C and 50 ± 5 % relative humidity for 48 hours are given in table 1:

Table 1

Observation	Specimen No				
	1	2	3	4	5
After flame time (sec) for each individual specimen, t_1	6	8	7	6	6
After flame time (sec) for each individual specimen, t_2	-	-	-	-	-
Afterglow time (sec) after second flame application, t_3	-	-	-	-	-
After flame or afterglow of any specimen up to the holding clamp	-	-	-	-	-
Cotton indicator ignited by flaming particles or droplets	No	No	No	No	No

The results for specimens conditioned at 70 ± 1 °C for 168 hours are given in table 2:

Table 2

Observation	Specimen No				
	1	2	3	4	5
After flame time (sec) for each individual specimen, t_1	5	7	8	8	7
After flame time (sec) for each individual specimen, t_2	-	-	-	-	-
Afterglow time (sec) after second flame application, t_3	-	-	-	-	-
After flame or afterglow of any specimen up to the holding clamp	-	-	-	-	-
Cotton indicator ignited by flaming particles or droplets	No	No	No	No	No


7 Requirements to meet UL classifications are given in the table below:

Observations	Classification requirements		
	V0	V1	V2
Total after flame time (sec) for each individual specimen t_1 or t_2	≤ 10	≤ 30	≤ 30
Total after flame time (sec) for all specimens subjected to test($t_1 + t_2$ for 5 samples)	≤ 50	≤ 250	≤ 250
Afterglow time (sec) after second flame application for each individual specimen	≤ 30	≤ 60	≤ 60
After flame or afterglow of any specimen up to the holding clamp	No	No	No
Cotton indicator ignited by flaming particles or droplets	No	No	Yes

8 Conclusion


The specimens tested satisfies the requirements given for a UL 94 rating V0, V1 and V2.

Prepared by



C. B. Chong
Fire Scientist

Approved by



S. Kumar
Technical Manager

Date of Issue: 19th July 2018

Date of Issue revision 1: 5th October 2018.

Report No: ICL/H18/9586 Rev 1

Page 4 of 4



No. 0307/ **2304**

To Duct Excel Co., Ltd.

The Department of Science Service presents the test report for the sample named "Polyisocyanurate (PIR) Foam" Laboratory No. L63/00695.1 as the total of 1 sample with reference to the request No. L63/00695 dated 23 January 2020.

Enclosed herewith the following result avails for your acknowledgement.



Division of Engineering Materials

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th



TEST REPORT

Sample's name

Polyisocyanurate (PIR) Foam

Mark / Brand

Duct Excel

Laboratory No.

L63/00695.1

Test Results

Flammability

- Flame class

The material identified in this report meets the criteria to qualify for HF-1 classification.

- Average linear burning rate, mm/min

0

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Laboratory No. L63/00695.1

Test item	Flame class			Results									
	HF-1	HF-2	HBF	Preconditioned at 23 °C, 50 % RH for 48 h					Preconditioned at 70 °C for 168 h				
- Specimen No.				1	2	3	4	5	1	2	3	4	5
- Thickness, mm				13.08	13.34	12.78	13.29	12.79	12.77	12.80	13.07	13.19	13.15
1.The duration of burning (t _b) between the 25 mm to the 125 mm mark ,sec		-	-	0	0	0	0	0	0	0	0	0	0
2.The distance the specimen burned (L _b) ,mm, between the 25 mm to the 125 mm mark	-	-	-	0	0	0	0	0	0	0	0	0	0
3.The burning rate , mm/min, over a 100 mm span, or	-	-	≤ 40 mm/min	0	0	0	0	0	0	0	0	0	0
4.Each specimen cease to burn before flaming or glowing reaches the 125 mm gauge mark	-	-	< 125 mm	25.0	28.0	23.0	22.0	28.5	28.0	29.5	27.5	23.0	25.0
5.Afterflame time, sec	4/5 is ≤ 2 s 1/5 is ≤10 s	4/5 is ≤2 s 1/5 is ≤10 s	-	0	6.5	0	0.5	0	4.5	0	0	0	0
6.Afterglow time for each individual specime, sec	≤ 30 s	≤ 30 s	-	0	0	0	0	0	0	0	0	0	0
7.Cotton indicator ignited by flaming particles or drops	No	Yes	-	No	No	No	No	No	No	No	No	No	No
8.Damaged length for each individual specimen, mm	< 60 mm	< 60 mm	-	25.0	28.0	23.0	22.0	28.5	28.0	29.5	27.5	23.0	25.0

Note : 1. Each specimen is 150 mm long and 50 mm wide.

2. 4/5 means four out of a set of five specimens.

3. 1/5 means one out of a set of five specimens.

Benjapant

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Laboratory No. L63/00695.1

Customer's name Duct Excel Co., Ltd.


Customer's address 1622/1 Sutthisan – Vinitchai Road, Huai Khwang, Hui Khwang, Bangkok
10310

Sample's description White foam sheet with metal foil in one side

Test date 24 January 2020 – 3 February 2020


Test method UL 94 Clause 12 Horizontal burning foamed material test

Approved by


(Mr. Anon Pomprasit)

Scientist, Senior Professional Level

Reported by


(Mr. Pongpiput Slangsing)

Scientist, Professional Level


This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be partially reproduced or manifested without the written permission from the Department of Science Service.

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Page 4/4

BS 476: Part 6: 1989+A1:2009



Method Of Test For Fire Propagation For Products

A Report To: Duct Excel Co., Ltd.

Document Reference: 398053

Date: 8th May 2018

Issue No.: 1

Page 1

Testing
Advising
Assuring

Executive Summary

Objective

To determine the performance of the following product when tested in accordance with BS 476: Part 6: 1989+A1: 2009.

Generic Description	Product reference	Thickness	Weight per unit area or density
Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium	"PID Panel: APA, APAX and SPA"	20mm	50kg/m ³
Individual components used to manufacture composite:			
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
PIR foam	"SAKEPOL S-200"	20mm	50kg/m ³
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
Please see page 5 of this test report for the full description of the product tested			

Test Sponsor

Duct Excel Co., Ltd., 1622/1 Suthisan Road, Huaykwang, Bangkok, Thailand, 10310

Test Results:


Fire propagation index, I = **3.2**
Sub index, i₁ = **1.4**
Sub index, i₂ = **0.9**
Sub index, i₃ = **0.9**


An uncertainty of measurement estimation has been conducted in relation to the fire propagation index, I and the sub index, i₁. The findings are as detailed in Annex A of this report.

Date of Test

27th & 30th April 2018

Signatories


Responsible Officer T. Mort * Senior Technical Officer


Authorised S. Deeming * Business Unit Head

* For and on behalf of **Exova Warringtonfire**.

Report Issued: 8th May 2018

This version of the report has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

CONTENTS

PAGE NO.

EXECUTIVE SUMMARY2

SIGNATORIES.....2

TEST DETAILS4

DESCRIPTION OF TEST SPECIMENS5

TEST RESULTS6

TABLE 1.....7

TABLE 2.....8

TABLE 3.....8

REVISION HISTORY10



Test Details

Purpose of test	<p>To determine the performance of a product when it is subjected to the conditions of the test specified in BS 476: Part 6: 1989+A1: 2009, "Fire tests on building materials and structures, method for fire propagation for products".</p> <p>The test was performed in accordance with the procedure specified in BS 476: Part 6: 1989+A1: 2009, and this report should be read in conjunction with that British Standard.</p>
Scope of test	BS 476: Part 6: 1989+A1: 2009 specifies a method of test, the result being expressed as a fire propagation index, that provides a comparative measure of the contribution to the growth of fire made by an essentially flat material, composite or assembly. It is primarily intended for the assessment of the performance of internal wall and ceiling linings.
Fire test study group/EGOLF	Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and have agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.
Instruction to test	The test was conducted on the 27 th & 30 th April 2018 at the request of Duct Excel Co., Ltd., the sponsor of the test.
Provision of test specimens	The specimens were supplied by the sponsor of the test. Exova Warringtonfire was not involved in any selection or sampling procedure.
Conditioning of specimens	<p>The specimens for testing to BS 476: Part 6: 1989+A1: 2009 together with the specimens for testing to BS 476: Part 7: 1997 were received on the 16th April 2018.</p> <p>Prior to the tests, all of the specimens were conditioned to constant mass at a temperature of $23 \pm 2^{\circ}\text{C}$ and a relative humidity of $50 \pm 5\%$. One specimen from the total sample submitted for test was selected for constant mass verification.</p>
Form in which the specimens were tested	Composite - Combination of materials which are generally recognised in building constructions as discrete entities e.g. coated or laminated materials.
Exposed face	One of two identical faces of the specimens was exposed to the heating conditions of the test.

Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. This information has not been independently verified by **Exova Warringtonfire**. All values quoted are nominal, unless tolerances are given.

General description		Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium
Product reference		"PID Panel: APA, APAX and SPA"
Name of manufacturer		Duct Excel Co., Ltd
Thickness		20mm (stated by sponsor) 20.4mm (determined by Exova Warringtonfire)
Density		50kg/m ³ (stated by sponsor) 72kg/m ³ (determined by Exova Warringtonfire)
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foam	Generic type	Polyisocyanurate (PIR) foam
	Product reference	"SAKEPOL S-200"
	Name of manufacturer	SAKE Co., Ltd. - Korea
	Thickness	20mm.
	Density	50kg/m ³
	Colour reference	"Light-Yellow"
	Flame retardant details	See Note 1 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Brief description of manufacturing process		Foaming polyisocyanurate (PIR) between embossed aluminium in continuous laminating machine

Note 1. The sponsor of the test was unwilling to provide this information.

Note 2. The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.

Test Results

Results

A total of three specimens were tested. The laboratory record sheet relating to each of the test specimens is appended to this report (refer to Tables 1, 2 and 3).

Throughout the test on each specimen careful observation was made of the product's behaviour within the apparatus and special note was taken of any of the phenomena listed in clause 9.2 of the Standard. None of the listed phenomena was observed and the test results on all three specimens tested were valid.

The following test results were obtained for the product.

Fire propagation index, I	=	3.2
Sub index, i_1	=	1.4
Sub index, i_2	=	0.9
Sub index, i_3	=	0.9

An uncertainty of measurement estimation has been conducted in relation to the fire propagation index, I and the sub index, i_1 . The findings are as detailed in Annex A of this report.

NOTE: If a suffix 'R' is included in the above fire propagation index, I, then this indicates that the results should be treated with caution.

Applicability of test result

The test results relate only to the behaviour of the test specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.

Validity

The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Exova Warringtonfire**.

Table 1

Laboratory Record Sheet
FIRE PROPAGATION TEST - BS476:PART 6:1989+A1:2009

Specimen No. : 1

Date : 27-Apr-18

Time mins t	Specimen Temperature Deg C Ts	Calibration Temperature Deg C Tc	Ts-Tc/10t	Sub Index Of Performance
0.50	14	13	0.20	1.18
1.00	21	19	0.20	
1.50	27	24	0.20	
2.00	33	28	0.25	
2.50	36	32	0.16	
3.00	41	36	0.17	
4.00	66	68	0.00	1.68
5.00	104	102	0.04	
6.00	137	132	0.08	
7.00	175	156	0.27	
8.00	197	174	0.29	
9.00	235	188	0.52	
10.00	246	198	0.48	
12.00	253	207	0.38	0.58
14.00	246	228	0.13	
16.00	246	236	0.06	
18.00	244	243	0.01	
20.00	240	249	0.00	
Total Index of Performance S			=	3.44

SubIndex s1 1.18

SubIndex s2 1.68

SubIndex s3 0.58

Index of Performance S 3.44

Table 2

Laboratory Record Sheet
FIRE PROPAGATION TEST - BS476:PART 6:1989+A1:2009

Specimen No. : 2

Date : 27-Apr-18

Time mins t	Specimen Temperature Deg C Ts	Calibration Temperature Deg C Tc	Ts-Tc/10t	Sub Index Of Performance
0.50	16	13	0.60	1.49
1.00	21	19	0.20	
1.50	27	24	0.20	
2.00	32	28	0.20	
2.50	36	32	0.16	
3.00	40	36	0.13	
4.00	71	68	0.08	0.42
5.00	107	102	0.10	
6.00	136	132	0.07	
7.00	157	156	0.01	
8.00	180	174	0.08	
9.00	190	188	0.02	
10.00	205	198	0.07	
12.00	250	207	0.36	1.15
14.00	288	228	0.43	
16.00	282	236	0.29	
18.00	256	243	0.07	
20.00	245	249	0.00	
Total Index of Performance S			=	3.06

SubIndex s1 1.49

SubIndex s2 0.42

SubIndex s3 1.15

Index of Performance S 3.06

Table 3

Laboratory Record Sheet

FIRE PROPAGATION TEST - BS476:PART 6:1989+A1:2009

Specimen No. : 3

Date : 30-Apr-18

Time mins t	Specimen Temperature Deg C Ts	Calibration Temperature Deg C Tc	Ts-Tc/10t	Sub Index Of Performance
0.50	16	13	0.60	1.51
1.00	23	19	0.40	
1.50	27	25	0.13	
2.00	33	31	0.10	
2.50	37	35	0.08	
3.00	45	39	0.20	
4.00	83	78	0.13	0.51
5.00	121	110	0.22	
6.00	150	144	0.10	
7.00	165	163	0.03	
8.00	183	182	0.01	
9.00	191	193	0.00	
10.00	207	205	0.02	
12.00	254	221	0.28	1.09
14.00	305	234	0.51	
16.00	285	244	0.26	
18.00	259	250	0.05	
20.00	249	256	0.00	
Total Index of Performance S			=	3.11

SubIndex s1 1.51

SubIndex s2 0.51

SubIndex s3 1.09

Index of Performance S 3.11

Annex A

Uncertainty of measurement

Specimen No.	1	2	3	Average
Fire propagation index, I	± 0.77	± 0.77	± 0.77	± 0.77
Sub index i_1	± 0.76	± 0.76	± 0.76	± 0.76


The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Revision History

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

BS 476: Part 7: 1997



Method For Classification Of The Surface Spread Of Flame Of Products

A Report To: Duct Excel Co., Ltd.

Document Reference: 398052

Date: 30th April 2018

Issue No.: 1

Page 1

Testing
Advising
Assuring

Executive Summary

Objective To determine the surface spread of flame classification of the following product when tested in accordance with BS 476: Part 7: 1997.

Generic Description	Product reference	Thickness	Weight per unit area or density
Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium	"PID Panel: APA, APAX and SPA"	20mm	50kg/m ³
Individual components used to manufacture composite:			
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
PIR foam	"SAKEPOL S-200"	20mm	50kg/m ³
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
Please see page 5 of this test report for the full description of the product tested			


Test Sponsor Duct Excel Co., Ltd., 1622/1 Suthisan Road, Huaykwang, Bangkok, Thailand, 10310

Test Results: **Class 1**


An uncertainty of measurement estimation has been conducted in relation to the distance travelled by the flame front and the findings are as detailed on page 8.

Date of Test 24th April 2018

Signatories



Responsible Officer
T. Mort *
Senior Technical Officer



Authorised
S. Deeming*
Business Unit Head

* For and on behalf of **Exova Warringtonfire**.

Report Issued: 30th April 2018

This version of the report has been produced from a pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

CONTENTS	PAGE NO.
EXECUTIVE SUMMARY	2
SIGNATORIES.....	2
TEST DETAILS.....	4
DESCRIPTION OF TEST SPECIMENS	5
TEST RESULTS	6
APPENDIX 1 – TEST RESULTS.....	7
APPENDIX 2 – CLASSIFICATION CRITERIA	9
REVISION HISTORY	10

Test Details

Purpose of test	To determine the performance of a product when it is subjected to the conditions of the test specified in BS 476: Part 7: 1997, "Fire tests on building materials and structures, method for classification of the surface spread of flame of products". This test was therefore performed in accordance with the procedure specified in BS 476: Part 7: 1997 and this report should be read in conjunction with that British Standard.
Scope of test	BS 476: Part 7: 1997 specifies a method of test for measuring the lateral spread of flame along the surface of a specimen of a product orientated in the vertical position, and a classification system based on the rate and extent of flame spread. It provides data suitable for comparing the performances of essentially flat materials, composites, or assemblies, which are used primarily as the exposed surfaces of walls or ceilings.
Fire test study group/EGOLF	Certain aspects of some fire test specifications are open to different interpretations. The Fire Test Study Group and EGOLF have identified a number of such areas and have agreed Resolutions which define common agreement of interpretations between fire test laboratories which are members of the Groups. Where such Resolutions are applicable to this test they have been followed.
Instruction to test	The test was conducted on the 24 th April 2018 at the request of Duct Excel Co., Ltd., the sponsor of the test.
Provision of test specimens	The specimens were supplied by the sponsor of the test. Exova Warringtonfire was not involved in any selection or sampling procedure.
Conditioning of specimens	<p>The specimens for testing to BS 476: Part 6: 1989+A1: 2009 together with the specimens for testing to BS 476: Part 7: 1997 were received on the 16th April 2018.</p> <p>Prior to the tests, all of the specimens were conditioned to constant mass at a temperature of $23 \pm 2^{\circ}\text{C}$ and a relative humidity of $50 \pm 5\%$. One specimen from the total sample submitted for test was selected for constant mass verification.</p>
Form in which the specimens were tested	Composite - Combination of materials which are generally recognised in building constructions as discrete entities e.g. coated or laminated materials. Each specimen was tested in direct contact with a nominally 12mm thick non-combustible backing board.
Exposed face	One of two identical faces of the specimens was exposed to the heating conditions of the test.

Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. This information has not been independently verified by **Exova Warringtonfire**. All values quoted are nominal, unless tolerances are given.

General description		Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium
Product reference		"PID Panel: APA, APAX and SPA"
Name of manufacturer		Duct Excel Co., Ltd
Thickness		20mm (stated by sponsor) 20.4mm (determined by Exova Warringtonfire)
Density		50kg/m ³ (stated by sponsor) 72kg/m ³ (determined by Exova Warringtonfire)
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foam	Generic type	Polyisocyanurate (PIR) foam
	Product reference	"SAKEPOL S-200"
	Name of manufacturer	SAKE Co., Ltd. - Korea
	Thickness	20mm.
	Density	50kg/m ³
	Colour reference	"Light-Yellow"
	Flame retardant details	See Note 1 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Brief description of manufacturing process		Foaming polyisocyanurate (PIR) between embossed aluminium in continuous laminating machine

Note 1. The sponsor of the test was unwilling to provide this information.

Note 2. The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.

Test Results

Results and observations

The test results for the individual specimens, together with observations made during the test and comments on any difficulties encountered during the test are given in Appendix 1.

Classification

In accordance with the class definitions given in BS 476: Part 7: 1997; the specimens tested are classified as Class 1.

An uncertainty of measurement estimation has been conducted in relation to the distance travelled by the flame front and the findings are as detailed on page 8.

Criteria for classification

If the prefix 'D' or suffix 'R' or 'Y' is included in the classification, this indicates that the results should be treated with caution. An explanation of the reason for the prefix and suffixes is given in Appendix 2, together with the classification limits specified in the Standard.

Applicability of test result

The test results relate only to the behaviour of the test specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product which is supplied or used is fully represented by the specimens which were tested.

Validity

The specification and interpretation of fire test methods are the subject of ongoing development and refinement. Changes in associated legislation may also occur. For these reasons it is recommended that the relevance of test reports over five years old should be considered by the user. The laboratory that issued the report will be able to offer, on behalf of the legal owner, a review of the procedures adopted for a particular test to ensure that they are consistent with current practices, and if required may endorse the test report.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Exova Warringtonfire**.

Appendix 1 – Test Results

SPECIMEN No.	1	2	3	4	5	6
Maximum distance travelled at 1.5 minutes (mm)	<50	<50	50	50	50	50
Distance (mm)	Time to travel to indicated distance (minutes : seconds)					
75						
165						
190						
215						
240						
265						
290						
375						
455						
500						
525						
600						
675						
710						
750						
785						
825						
Time to reach maximum distance travelled	1:00	1:00	1:00	1:00	1:00	1:00
Maximum distance travelled in 10 minutes (mm)	<50	<50	50	50	50	50

Note: Six specimens are usually tested. If the test on any specimen is deemed to be invalid, as defined in the Standard, it is permissible for up to a maximum of nine specimens to be tested in order to obtain the six valid test results.

Observations made during test and comments on any difficulties encountered during the test:

In the case of each specimen tested, blistering of the surface was observed, extending up to a maximum distance of 240mm.

**Uncertainty of
measurement**

Specimen No.	1	2	3	4	5	6
Maximum distance travelled at 1.5 minutes (mm)	±0	±0	±3	±3	±3	±3
Maximum distance travelled in 10 minutes (mm)	±0	±0	±3	±3	±3	±3

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Appendix 2 – Classification Criteria

Classification of spread of flame

Classification	Spread of Flame at 1.5 min		Final Spread of Flame	
	Limit (mm)	Limit for one specimen (mm)	Limit (mm)	Limit for one specimen (mm)
Class 1	165	165 + 25	165	165 + 25
Class 2	215	215 + 25	455	455 + 45
Class 3	265	265 + 25	710	710 + 75
Class 4	Exceeding the limits for class 3			

Explanation of prefix and suffixes which may be added to the classification

1. A suffix R is added to the classification if more than six specimens are required in order to obtain six valid test results (e.g. class 2R).
2. A prefix D is added to the classification of any product which does not comply with the surface characteristics specified in the Standard and has therefore been tested in a modified form (e.g. class D3).
3. A suffix Y is added to the classification if any softening and/or other behaviour that may affect the flame spread occurs (e.g. class 3Y).


For example, a classification of D3RY could be achieved indicating (a) a modified surface has been used; (b) a class 3 result has been obtained; (c) additional specimens have been used to obtain 6 valid results and; (d) softening and/or other behaviour has occurred which is considered to have affected the test result.

Revision History

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Class 0 Summary Report



Including Opinion Of Compliance With The Requirements For A Class 0 Surface As Defined In Paragraph A13(b) Of Approved Document B (Volumes 1 & 2), (2006 Edition) 'Fire Safety' To The Building Regulations 2000

Date: 8th May 2018

Issue No.: 1

Page 1

A Report To: Duct Excel Co., Ltd.

Document Reference: 398052 & 398053

**Testing
Advising
Assuring**

Executive Summary

Objective

To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of the following product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.

Generic Description	Product reference	Thickness	Weight per unit area or density
Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium	"PID Panel: APA, APAX and SPA"	20mm	50kg/m ³
Individual components used to manufacture composite:			
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
PIR foam	"SAKEPOL S-200"	20mm	50kg/m ³
Embossed aluminium foil	Not stated	80 microns	0.25kg/m ²
Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium			

Test Sponsor

Duct Excel Co., Ltd., 1622/1 Suthisan Road, Huaykwang, Bangkok, Thailand, 10310


Opinion:

We consider the results of the tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7: 1997, demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document B, 'Fire Safety', to the Building Regulations 2000.


Date of Test

24th, 27th & 30th April 2018

Signatories



Responsible Officer
T. Mort*
Senior Technical Officer



Authorised
S. Deeming *
Business Unit Head

* For and on behalf of **Exova Warringtonfire**.

Report Issued: 8th May 2018

This version of the report has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

CONTENTS	PAGE NO.
EXECUTIVE SUMMARY	2
SIGNATORIES.....	2
TEST DETAILS.....	4
DESCRIPTION OF TEST SPECIMENS.....	5
CLASSIFICATION	6
REVISION HISTORY	7

Test Details

Terms Of Reference To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of a product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.

Introduction Specimens of a product have been tested in accordance with the test methods specified in BS 476: Part 6: 1989+A1: 2009 'Method of test for fire propagation for products' and BS 476: Part 7: 1997 'Method of test to determine the classification of the surface spread of flame of products'. The results of the tests are fully reported in the **Exova Warringtonfire** test reports No's. 398052 and 398053.

This summary test report has been prepared at the request of the sponsor and relates the results of the tests to the requirements for a Class 0 surface of a material or composite product, as defined in paragraph A13(b) of Approved Document B, 'Fire Safety', to the Building Regulations 2000.

This summary should be read in conjunction with, and not accepted as a substitute for, the **Exova Warringtonfire** test reports No's. 398052 and 398053. Those test reports may include additional information which may be relevant to the assessment of the potential fire hazard of the product.

Face subjected to tests The specimens were mounted in the test positions such that one of two identical faces was exposed to the heating conditions of the tests.

Results of test The following results were obtained for the specimens, which were tested.

BS 476: Part 6: 1989+A1: 2009	Fire propagation index, I	=	3.2
	subindex, i_1	=	1.4
	subindex, i_2	=	0.9
	subindex, i_3	=	0.9

BS 476: Part 7: 1997

Class 1 surface spread of flame

The test results relate only to the behaviour of the test specimens of the product under the particular conditions of the test, they are not intended to be the sole criterion for assessing the potential hazard of the product in use.

Description of Test Specimens

The description of the specimens given below has been prepared from information provided by the sponsor of the test. This information has not been independently verified by **Exova Warringtonfire**. All values quoted are nominal, unless tolerances are given.

General description		Rigid polyisocyanurate (PIR) foam panel faced on both sides with embossed aluminium
Product reference		"PID Panel: APA, APAX and SPA"
Name of manufacturer		Duct Excel Co., Ltd
Thickness		20mm (stated by sponsor) 20.4mm (determined by Exova Warringtonfire)
Density		50kg/m ³ (stated by sponsor) 72kg/m ³ (determined by Exova Warringtonfire)
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foam	Generic type	Polyisocyanurate (PIR) foam
	Product reference	"SAKEPOL S-200"
	Name of manufacturer	SAKE Co., Ltd. - Korea
	Thickness	20mm.
	Density	50kg/m ³
	Colour reference	"Light-Yellow"
	Flame retardant details	See Note 1 below
Adhesive	The foil was auto-adhesively bonded to the foam during the manufacturing process	
Foil	Generic type	Embossed aluminium
	Product reference	See Note 1 below
	Detailed description / composition details	See Note 1 below
	Name of manufacturer	See Note 1 below
	Thickness	80 microns
	Weight per unit area	0.25kg/m ²
	Colour reference	"Silver"
	Flame retardant details	See Note 2 below
Brief description of manufacturing process		Foaming polyisocyanurate (PIR) between embossed aluminium in continuous laminating machine

Note 1. The sponsor of the test was unwilling to provide this information.

Note 2. The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the component.

Classification

Opinion

We consider the results of the tests detailed above demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document B, 'Fire Safety', to the Building Regulations 2000.

Validity of opinion

This opinion is based on the requirements of the Building Regulations at the date of this report. If the Building Regulations are revised or amended in any way subsequent to that date, care must be taken to ensure that this opinion is not invalidated by those revisions or amendments.

The opinion has been formulated on the assumption that the specimens are representative of the product in practice. **Exova Warringtonfire** was not involved in any sampling or selection procedures which would confirm this or in any audit testing which would provide confidence in the consistency of the product in the tests.

This report may only be reproduced in full. Extracts or abridgements shall not be published without permission of **Exova Warringtonfire**.

Revision History

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Re-issue Date:
Revised By:	Approved By:
Reason for Revision:	

ASTM E 84 Surface Burning Characteristics of "PID Panel (Pre-Insulated Duct Panel)"

A Report To:	Duct Excel Co., Ltd. 1622/1 Suthisan-Vinijchai Road Huaykwang, Bangkok 10310 Thailand
Phone:	+1 66632244996
Attention:	Trinnatee Chotimongkol
E-mail:	trinnatee@ductexcel.co.th
Submitted by:	Element Fire Testing
Report No.	22-002-270(Revision 1) 4 Pages
Date:	July 12, 2022

1.0 ACCREDITATION

ISO/IEC 17025 for a defined Scope of Testing by the American Association for Laboratory Accreditation (A2LA)

2.0 SPECIFICATIONS OF ORDER

Determine the Flame Spread and Smoke Developed Indices based upon a single test conducted in accordance with ASTM E 84-22, as per Element Quotation No. 22-002-363045 dated June 15, 2022.

2.1 History of Revision

This report supersedes Element Test Report No. 22-002-270, originally issued on July 11, 2022. It is revised to amend the reported sample thickness in Section 5.0.

3.0 SAMPLE IDENTIFICATION (Element sample identification number 22-002-S0270)

Faced, insulated panel system described as, "Polyisocyanurate Foam (PIR)", and identified as:
"PID Panel (Pre-Insulated Duct Panel)"

4.0 TEST PROCEDURE

The method, designated as ASTM E 84-22 "*Standard Method of Test for Surface Burning Characteristics of Building Materials*", is designed to determine the relative surface burning characteristics of materials under specific test conditions, where the material under test is mounted so that it forms the ceiling of a horizontal fire tunnel. A specified airflow is introduced through the tunnel and a specified flame is applied to one end. Observations are then made regarding the rate of flame spread along the specimen. Results are expressed in terms of Flame Spread Index (FSI) and Smoke Developed Index (SDI). There is no established relationship between those two values.

Although the procedure is applicable to materials, products and assemblies used in building construction for development of comparative surface spread of flame data, the test results may not reflect the relative surface burning characteristics of tested materials under all building fire conditions.

5.0 SAMPLE PREPARATION

The test specimen consisted of a total of five sections of material, each approximately 0.787 inches (20 mm) in total thickness by 21 inches (533 mm) in width by 58 inches (1473 mm) in length. The sections were butted together to create the specimen length. The integrated aluminum end flanges were left in-place during testing. Prior to testing, the specimen was conditioned to constant weight at a temperature of $73 \pm 5^{\circ}\text{F}$ ($23 \pm 3^{\circ}\text{C}$) and a relative humidity of $50 \pm 5\%$. During testing, the metal facer surface was exposed to the test flame, as marked.

The testing was performed on: 2022-07-11

6.0 SUMMARY OF TEST PROCEDURE

The tunnel is preheated to $150 \pm 5^{\circ}\text{F}$ ($66 \pm 2.8^{\circ}\text{C}$), as measured by the floor-embedded thermocouple located 23.25 feet (7087 mm) downstream of the burner ports, and is allowed to cool to $105 \pm 5^{\circ}\text{F}$ ($40.5 \pm 2.8^{\circ}\text{C}$), as measured by the floor-embedded thermocouple located 13 feet (3962 mm) from the burners. The tunnel lid is then raised and the test specimen is placed along the ledges of the tunnel so as to form a continuous ceiling 24 feet (7315 mm) long, approximately 12 inches (305 mm) above the floor. Three 8 foot (2438 mm) sections of 0.25 inch (6 mm) cement board are then placed on the back side of the specimen and the lid is then lowered into place.

Upon ignition of the gas burners, the flame spread distance is observed and recorded every second. Flame spread distance versus time is plotted. Calculations ignore all flame front recessions and Flame Spread Index (FSI) is determined by calculating the total area under the curve for the test sample. If the area under the curve (A) is less than or equal to 97.5 min·ft, then $FSI = 0.515 \cdot A$; if greater, $FSI = 4900 / (195 - A)$. FSI is then rounded to the nearest multiple of 5.

Smoke Developed Index (SDI) is determined by dividing the total area under the obscuration curve by that established for liquid heptane, and multiplying by 100. SDI is then rounded to the nearest multiple of 5 if less than 200. SDI values over 200 are rounded to the nearest multiple of 50.

7.0 TEST RESULTS

SAMPLE: "PID Panel (Pre-Insulated Duct Panel)"

Approx. Time to Ignition (s)	Maximum Flame Front Distance	Time to Maximum Flame Front (s)	Flame Spread Index (FSI)	Smoke Developed Index (SDI)
69	(ft.): 5.1 (m): 1.55	293	20	250

7.1 Observations of Burning Characteristics

The material ignited approximately 69 seconds after exposure to the test flame. The metal facing material was observed to split at approximately 45 seconds.

8.0 INTERPRETATION OF RESULTS

Industry documents such as the International Building Code (IBC) or NFPA 101 Life Safety Code refer to ASTM E 84 (UL 723, NFPA 255) test results using the following material classification categories:

	Flame-Spread Index (FSI)	Smoke Developed Index (SDI)
Class 1 or Class A	0 - 25	450 Maximum
Class 2 or Class B	26 - 75	450 Maximum
Class 3 or Class C	76 - 200	450 Maximum
Results Classification (if applicable):		Class 1 or Class A



Francis Williams,
Technician.



Ian Smith,
Technical Manager.

Notes: This report is related only to the sample identified and shall not be reproduced, except in full, without approval. It is covered under Element Materials Technology Canada Inc. Standard Terms and Conditions of Contract, which are accessible at www.element.com, or by calling 1-866-263-9268. ASTM E 84 is a well-established test method that reports data in the form of indices. As such, MU cannot be calculated. In the reporting instructions, calculated values are rounded to the nearest multiple of 5 for FSI, and 5 or 50 for SDI, depending on the result. Since the rounding ranges establish precision and include potential uncertainty, by following the reporting instructions, the lab is considered to have satisfied the MU reporting requirements of ISO/IEC 17025.

9.0 TEST CHARTS

ASTM E 84-22

Sample: "PID Panel (Pre-Insulated Duct Panel)"

Chart 1. FLAME SPREAD





Chart 2. SMOKE DEVELOPED



Calculated Flame Spread (CFS)	Rounded Flame Spread Index (FSI)	Calculated Smoke Developed (CSD)	Rounded Smoke Developed Index (SDI)	Maximum 23' Air Temperature (°F)
20.1	20	262.3	250	481

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

TEST REPORT

Client : Duct Excel Co.,Ltd
1622/1 Sutthisan-Vinitchai Road
Huai Khwang,Huai Khwang
Bangkok 10310 Thailand

Test Number : 20-004810
Issue Date : 1/10/2020
Print Date : 1/10/2020

Sample Description Clients Ref : "Pre-Insulated PIR Duct Panel"
Rigid Ducting
Colour : Silver
End Use : Ducting

UL 181.11-2013

Burning Test - Air Duct

Date of Testing	01/10/2020		
Sample Tested	Assembly		
External	Vertical	45 deg	Horizontal
1st after flame time	0	0	0 sec
1st after glow time	0	0	0 sec
2nd after flame time	0	0	0 sec
2nd after glow time	0	0	0 sec
Did flaming or glowing travel full length of specimen ?	No	No	No
Did flaming droplets ignite cotton ?	N/A	No	No
Internal	Vertical	45 deg	Horizontal
1st after flame time	0	0	0 sec
1st after glow time	0	0	0 sec
2nd after flame time	0	0	0 sec
2nd after glow time	0	0	0 sec
Did flaming or glowing travel full length of specimen ?	No	No	No

216338

46743

Page 1 of 1



Test Report 4681859

Date : 17-Aug-2020

Page 1 of 5

Client : DUCT EXCEL CO.,LTD

1622/1 Suthisarn-Vinitchai Road, Huaykwang, Huaykwang, Bangkok 10310 Thailand

The following sample(s) was/were submitted and identified by client as:

Sample Name : Aluminium Foil
Sample Description : Antibacterial Coating

The following sample(s) was/were identified by SGS as:

SGS Sample No. : 4843657
Sample Condition : Sample is contained in a plastic bag.
Quantity Submitted : 12 pcs

Date Received : 4-Aug-2020

Date Commenced : 5-Aug-2020

**Signed for and on behalf of
SGS (Thailand) Limited**



**Jirapan Vilaipol
Microbiological Lab Manager**

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

4383572 This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.
Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.
Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only."
WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

TEST RESULTS

Test Required : Antibacterial activity and efficacy (Quantitative) - Staphylococcus aureus ATCC 6538P (and)
- Escherichia coli ATCC 8739

Test Method : Based on JIS Z 2801:2010

Tested microorganism	Concentration of bacteria (CFU/ml)	Initial inoculum concentration (CFU/piece of samples)	The number of bacteria recovered from control at 0 hr. contact time(CFU/piece of samples)	The number of bacteria recovered from control at 24 hrs. contact time(CFU/piece of samples)	The number of bacteria recovered from tested sample at 24 hrs. contact time(CFU/piece of samples)	Value of antimicrobial activity(R)	%Reduction
<i>Staphylococcus aureus</i> ATCC 6538P	720,000	290,000 (5.5 log)	270,000 (5.4 log)	350,000 (5.5 log)	50 (1.7 log)	3.8	99.98
<i>Escherichia coli</i> ATCC 8739	300,000	120,000 (5.1 log)	100,000 (5.0 log)	6,000,000 (6.8 log)	40 (1.6 log)	5.2	99.96

Remark

- The % Reduction is calculated based on customer's requirement.
- % Reduction = $(A-B)/A \times 100$
where,
A = The number of bacteria recovered from control at 0 hrs. contact time(CFU/piece of samples)
B = The number of bacteria recovered from tested sample at 24 hrs. contact time(CFU/piece of samples)
- $R = (U_t - U_o) - (A_t - U_o) = U_t - A_t$

Where, R : antibacterial activity

U_o : average of logarithm numbers of viable bacteria immediately after inoculation on untreated test piece

U_t : average of logarithm numbers of viable bacteria after inoculation on untreated test piece after 24 h

A_t : average of logarithm numbers of viable bacteria after inoculation on antibacterial test piece after 24 h

Criteria : The value of antimicrobial activity obtained by the testing methods of this standard shall not be less than 2.0

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.



Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."

Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only."

WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



SAMPLE/ATTACHMENT PICTURE



"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

4383572 This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.
Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.
Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only."
WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SAMPLE/ATTACHMENT PICTURE



"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

4383572 This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.
 Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
 Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.
 Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only."
 WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

SAMPLE/ATTACHMENT PICTURE



***** End of Report *****

"Any holder of this document is advised that should client or third party information be supplied with respect to the goods or sample, SGS may, at its discretion, attached or indicate such information to the report but SGS makes no warranties or accepts no liable for the veracity or lack thereof of such Information."

4383572

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request.
 Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."
 Publish or advertisement of the result or this document is prohibited, unless prior written approval of the Company.
 Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only."
 WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



No. 0307/ **6449**

To Duct Excel Co., Ltd.

The Department of Science Service presents the test report for the sample named “PVC Flanges for Pre-insulated Duct Panel (PID) Accessories” Laboratory No. L67/03080.1 as the total of 1 sample with reference to the request No. L67/03080 dated 4 April 2024.

Enclosed herewith the following results avail for your acknowledgement.



Division of Engineering Materials

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th



TEST REPORT

Sample's name

PVC Flanges for Pre-insulated

Duct Panel (PID) Accessories

Mark / Brand

Duct Excel

Laboratory No.

L67/03080.1

Test Results

Flammability test**Flame class**


The material identified in this report meets the criteria to qualify for V-0 classification.

This report is only valid for the sample received. The report shall not be reproduced except in full

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Test item	Flame class			Results									
	V-0	V-1	V-2	Preconditioned at 23 °C, 50% RH for 48 hours					Preconditioned at 70 °C for 168 hours				
				1	2	3	4	5	1	2	3	4	5
- Specimen No.													
- Thickness, mm				1.79	1.78	1.80	1.78	1.80	1.80	1.82	1.77	1.79	1.80
1. Afterflame time after first flame application for each individual specimen t_1 , s	≤ 10	≤ 30	≤ 30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2. Afterflame time after second flame application for each individual specimen t_2 , s	≤ 10	≤ 30	≤ 30	0.5	0.0	4.0	0.5	6.5	2.0	5.5	4.5	4.0	1.5
3. Afterglow time after second flame application for each individual specimen t_3 , s		-	-	0.0	1.5	0.5	0.0	0.5	0.5	0.0	0.0	0.0	0.0
4. Total afterflame time for any condition set ($t_1 + t_2$ for the 5 specimens), s	≤ 50	≤ 250	≤ 250	11.5					17.5				
5. Afterflame plus afterglow time for each individual specimen after the second flame application ($t_2 + t_3$), s	≤ 30	≤ 60	≤ 60	0.5	1.5	4.5	0.5	7.0	2.5	5.5	4.5	4.0	1.5
6. Afterflame or afterglow of any specimen up to the holding clamp	No	No	No	No	No	No	No	No	No	No	No	No	No
7. Cotton indicator ignited by flaming particles or drops	No	No	Yes	No	No	No	No	No	No	No	No	No	No



This report is only valid for the sample received. The report shall not be reproduced except in full

Department of Science Service, Ministry of Higher Education Science Research and Innovation

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Laboratory No. L67/03080.1

Customer's name Duct Excel Co., Ltd.

Customer's address 1622/1 Suthisarn vinijchai Rd, Huai Khwang, Huai Khwang, Bangkok
Thailand 10310

Sample's description Grey rigid sheet

Test date 17 - 24 April 2024

Test method UL 94 Clause 8 ((20 mm) Vertical Burning Test ; V-0, V-1 or V-2)


Approved by



(Mr. Jaroon Junsomboon)

Scientist, Senior Professional Level

Reported by



(Mr. Pongpiput Slangsing)

Scientist, Professional Level

This report is only valid for the sample received. The report shall not be reproduced except in full

Department of Science Service, Ministry of Higher Education Science Research and Innovation


Rama VI Road, Ratchathewi, Bangkok 10400, Thailand



ISO 9001 : 2015



PID PANEL Portfolio



Project References :

Department Stores


Factories

Hospitals

Hotels & Condominiums

Office Buildings

Other Projects



Department Stores :

- เดอะมอลล์ บางกะปิ
- เดอะมอลล์ บางแค
- SIAM PARAGON (Renovate)
- KING POWER รางน้ำ
- POWER BUY โรบินสันลาดกระบัง
- FOOD COURT โรบินสันลาดกระบัง
- FOOD COURT แฟชั่นไอส์แลนด์
- SUPER SPORT เซ็นทรัลสุพรรณภูมิ
- ADIDAS เซ็นทรัลลาดกระบัง
- POWER BUY โรบินสัน – สุพรรณบุรี
- POWER BUY ราชพฤกษ์




Department Stores

เดอะมอลล์ บางกะปิ




Department Stores

เดอะมอลล์ บางแค




Department Stores

SIAM PARAGON (Renovate)



Department Stores

FOOD COURT แฟชั่นไอส์แลนด์



โดย บริษัท

Department Stores

FOOD COURT โรบินสันลาดกระบัง - กรุงเทพฯ



Factories :

- KCE ELECTRONICS HUB – ลาดกระบัง
- JASPER- บางพลี
- LUMENTUM – นวนคร ปทุมธานี
- เบสซี คลอง 8 – ปทุมธานี
- NEO FACTORY – คลอง 13 ปทุมธานี
- OHLINS ADVANCED SUSPENSION TECHNOLOGY – ชลบุรี
- PPN MARKETING – บางปะกง
- ไทยรวมสินพัฒนาอุตสาหกรรม – สมุทรสาคร







Factories


โรงงาน NEO FACTORY – คลอง 13 ปทุมธานี



Factories


JASPER - บางพลี





Factories

OHLINS ADVANCED SUSPENSION TECHNOLOGY - ชลบุรี



Office Buildings :

- สำนักงานใหญ่ ไทยน้ำทิพย์ นอร์ทปาร์ค
- สำนักงานกองทุนเพื่อการศึกษา – ดิ깅 IBM พหลโยธิน
- Mitsubishi Electric Kang Yong Wattana
- กรมศุลกากร
- บริษัท ดีเคเอสเอช (ประเทศไทย) จำกัด
- ธนาคารยูโอบี – สุขุมวิท
- อาคารพหลโยธินเพลส (ส่วนปรุ้งปรุ้ง)
- อาคารธนบุรีพานิช – บางพลัด กรุงเทพฯ
- บริษัท แกร็บแท็กซี่ (ประเทศไทย) จำกัด – พระราม 4
- บริษัท เอ็นอาร์ที เซลส์ แอนด์ เซอร์วิส จำกัด – ปทุมธานี
- บริษัท กมลพิศาลกระจกนิรภัย จำกัด – นครศรีธรรมราช




Office Buildings

สำนักงานใหญ่ ไทยน้ำทิพย์ นอร์ทปาร์ค



Office Buildings

กรมศุลกากร - กรุงเทพฯ



โดย บริษัท เอส เอส อัลลายแอนซ์

Office Buildings

อาคารพหลโยธินเพลส



โดย บริษัท เอสดักท์ เอ็นจิเนียริ่ง

Office Buildings

บริษัท ดีเคเอสเอช (ประเทศไทย) จำกัด - กรุงเทพฯ



Office Buildings



ธนาคารไอบี – สุขุมวิท กรุงเทพฯ



โดย บริษัท พาส409 เอ็นจิเนียริง

Office Buildings

บริษัท เอ็นอาร์ที เซลส์ แอนด์ เซอร์วิส จำกัด - ปทุมธานี



Office Buildings

บริษัท กมลพิศาลกระจกนิรภัย จำกัด - นครศรีธรรมราช



Hospitals :

- โรงพยาบาลวิภาวดี
- โรงพยาบาลลาดพร้าว
- โรงพยาบาลตำรวจ
- สถาบันโรคผิวหนัง อนุเสาวรีย์
- โรงพยาบาลนวเวช – นวมินทร์
- โรงพยาบาลอินทรารัตน์ – รามอินทรา
- โรงพยาบาลบางโพ
- อาคารคลินิกความงาม แยกพระราม 9
- โรงพยาบาลสินแพทย์ ลำลูกกา
- โรงพยาบาลสินแพทย์ ห้องผ่าตัด - นครปฐม (SPA)
- โรงพยาบาลบางบัวทอง



Hospitals :

- โรงพยาบาลนครพิงค์ – เชียงใหม่
- โรงพยาบาลมหาราชนครเชียงใหม่
- โรงพยาบาลท่าสองยาง – ตาก
- โรงพยาบาลมหาสารคาม ห้องคลีนรูม
- โรงพยาบาลรวมแพทย์ – ฉะเชิงเทรา
- โรงพยาบาลอภัยภูเบศร - ปราจีนบุรี
- โรงพยาบาลมหาราช – นครราชสีมา
- โรงพยาบาลอุตรดิตถ์ ห้องแรงดันลบ Covid-19
- โรงพยาบาลปัตตานี
- รพ.บ้านนั้งस्ता - ยะลา



Hospitals :

- โรงพยาบาลตำรวจ อาคารรักษาพยาบาลและฟื้นฟูข้าราชการตำรวจ แยกราชประสงค์
- โรงพยาบาลจุฬาลงกรณ์ คลินิกผู้ป่วยนอก อาคาร ภาปร.

Hospitals

โรงพยาบาลลาดพร้าว - กรุงเทพฯ



Hospitals

โรงพยาบาลตำรวจ - กรุงเทพฯ







โดย เอสซีเจ แอร์คัทท์



Hospitals

โรงพยาบาลสินแพทย์ ห้างผ้าตัด - นครปฐม (SPA)



Hospitals

โรงพยาบาลบางบัวทอง – นนทบุรี



โดย บริษัท วีเค แอ็พพลาย

โรงพยาบาลอุดรดิตถ์ - ห้องแรงดันลบ Covid-19



Hospitals

โรงพยาบาลมหาวิทยาลัยเชียงใหม่- เชียงใหม่



โดย บริษัท แมริม เอ็นจิเนียริง



Hotels & Condominiums :

- CENTARA อรุณยา
- Santiburi The Residences รามอินทรา
- บางกอก บูเลอวาร์ด รามอินทรา
- โรงแรมแมนดาริน บางรัก
- Dusit D2S Samyan
- Sand Dunes Chaolao Beach Resort – จันทบุรี
- Andaz Pattaya Jomtien Beach-พัทยา
- คีรีมายา เรสซิเดนส์ เขาใหญ่



Hotels & Condominiums

CENTARA อัญญา






Hotels & Condominiums

โครงการ Santiburi The Residences - กรุงเทพฯ



โดย บริษัท นีโอ727



Hotels & Condominiums

Andaz Pattaya Jomtien Beach




โดย บริษัท 101 เอ็นจิเนียริง



Hotels & Condominiums


คิรีมายา เรสซิเดนส์ เขาใหญ่



โดย บริษัท เอ็มอีพี ซิสเต็ม

Hotels & Condominiums

Dusit D2 Samyan



โดย บริษัท เอ็มไลน์ เอจีเนียริง แอนด์ คอนสตรัคชั่น

Hotels & Condominiums

Sand Dunes Chaolao Beach Resort - จันทบุรี



Other Projects :

- พิพิธภัณฑ์พระรามเก้า
- พิพิธภัณฑ์บ้านปาร์ค นายเลิศ
- วัดมัจฉนันทิการาม
- บ้านพักเอกอัครราชทูตอเมริกา
- สนามยิงปืน การกีฬาแห่งประเทศไทย
- โรงเรียนมาแตร์เดอีวิทยาลัย
- ร้านอาหาร KING KONG - สายไหม 53
- La Chapelle Bangkok (สตูดิโอและสถานที่จัดงาน)-บางเขน
- STARBUCK – เชียงร้งสิต






Other Projects :

- โบสถ์คริสต์ – นครปฐม
- ร้านปิ้งคำหอม – ราชบุรี
- ร้านปิ้งคำหอม – กาญจนบุรี
- วัดธารทหาร จ.นครสวรรค์



Other Projects


พิพิธภัณฑสถานพระราม9 - กรุงเทพฯ



โดย บริษัท เจ แอนด์ เจ แอร์ เทคโนโลยี

Other Projects


Studio - La Chapelle Bangkok



โดย หจก. พีแอร์ กรุ๊ป


Other Projects

วัดมัสญิดนติการาม - กรุงเทพฯ



Other Projects

บ้านพักเอกอัครราชทูตอเมริกา - กรุงเทพฯ



โดย บริษัท ชัน ซิสเต็ม

Other Projects

โรงเรียนมาแตร์เดอีวิทยาลัย - กรุงเทพฯ

